



Environmental Laboratory Services Ltd.

Hutt City Council (Capacity)NR
Wellington Water Management
Private Bag 39-804
WELLINGTON MAIL CENTRE

Analytical Report

Report Number: 07/7315

Issue: 1
03 May 2007

Attention: Gary O'Meara

| Sample | Site | Map Ref. | Date Sampled | Date Received | Order No. |
|------------|-----------------------|----------|------------------|---------------|-----------|
| 07/7315-01 | Domestic Water Supply | | 23/04/2007 07:30 | 23/04/2007 | 0 |

Notes: Lower Hutt Water Supply

| Test | Result | Units | Comments | Signatory |
|------------------------------|---------|-------------------------------------|-----------------------------|------------------------|
| 0001 pH | 7.3 | | Complies with NZDW Standard | Rachel Wallace KTP/LAS |
| 0052 Alkalinity - Total | 58 | g CaCO ₃ /m ³ | No limit listed in NZDWS | Rachel Wallace KTP/LAS |
| 0055 Conductivity at 25°C | 19.1 | mS/m | No limit listed in NZDWS | Rachel Wallace KTP/LAS |
| 0058 Free Available Chlorine | < 0.1 | g/m ³ | Complies with NZDW Standard | Rachel Wallace KTP/LAS |
| 0084 Turbidity | 0.72 | NTU | Complies with NZDW Standard | Rachel Wallace KTP/LAS |
| 0103 Total Coliforms | <1 | /100mL | No limit listed in NZDWS | Sunita Raju KTP/LAS |
| 0104 E. coli | <1 | /100mL | Complies with NZDW Standard | Sunita Raju KTP/LAS |
| 0601 Fluoride | 0.81 | g/m ³ | Complies with NZDW Standard | Rob Deacon KTP/LAS |
| 0602 Chloride | 15.7 | g/m ³ | Complies with NZDW Standard | Rob Deacon KTP/LAS |
| 0605 Nitrate - Nitrogen | 0.76 | g/m ³ | Complies with NZDW Standard | Rob Deacon KTP/LAS |
| 0607 Sulphate | 5.92 | g/m ³ | Complies with NZDW Standard | Rob Deacon KTP/LAS |
| 1602 Arsenic - Acid Soluble | < 0.005 | g/m ³ | Complies with NZDW Standard | Wayne Edgerley KTP/LAS |
| 1606 Boron - Acid Soluble | 0.021 | g/m ³ | Complies with NZDW Standard | Wayne Edgerley KTP/LAS |
| 1610 Calcium - Acid Soluble | 20.6 | g/m ³ | See Total Hardness | Wayne Edgerley KTP/LAS |
| 1615 Copper - Acid Soluble | < 0.005 | g/m ³ | Complies with NZDW Standard | Wayne Edgerley KTP/LAS |

Report Number: 07/7315-1

85 Port Road Seaview
Lower Hutt New Zealand

Page 1 of 3

03 May 2007 15:29:19

Phone: (04) 576 5016 Fax: (04) 576 5017

Email: <mailto:rdeacon@els.co.nz> Website: <http://www.els.co.nz>

| Sample | Site | Map Ref. | Date Sampled | Date Received | Order No. |
|--------------------------------|-----------------------|----------|-----------------------------|------------------------|-----------|
| 07/7315-01 | Domestic Water Supply | | 23/04/2007 07:30 | 23/04/2007 | 0 |
| Notes: Lower Hutt Water Supply | | | | | |
| Test | Result | Units | Comments | Signatory | |
| 1619 Iron - Acid Soluble | 0.178 | g/m3 | Complies with NZDW Standard | Wayne Edgerley KTP/LAS | |
| 1622 Magnesium - Acid Soluble | 2.94 | g/m3 | See Total Hardness | Wayne Edgerley KTP/LAS | |
| 1623 Manganese - Acid Soluble | < 0.005 | g/m3 | Complies with NZDW Standard | Wayne Edgerley KTP/LAS | |
| 1634 Sodium - Acid Soluble | 10.9 | g/m3 | Complies with NZDW Standard | Wayne Edgerley KTP/LAS | |
| 1641 Zinc - Acid Soluble | < 0.005 | g/m3 | Complies with NZDW Standard | Wayne Edgerley KTP/LAS | |
| 1642 Total Hardness | 64 | g/m3 | Complies with NZDW Standard | Wayne Edgerley KTP/LAS | |

Comments:

Sampled by ELS using approved containers and techniques.

All samples analysed as we receive them. Delivery was within the correct time and temperature conditions.

Test Methodology:

| Test | Methodology | Detection Limit |
|--------------------------|--|-----------------|
| pH | APHA 21st Edition Method 4500 H. LAS official test 4.3, 5.03. | 0.1 |
| Alkalinity - Total | APHA 20th Edition Method 2320 B | 1 g CaCO3/m3 |
| Conductivity at 25°C | APHA 20th Edition Method 2510 B. LAS official test 4.2, 5.02. | 0.1 mS/m |
| Free Available Chlorine | APHA 20th Edition Method 4500-Cl G | 0.1 g/m3 |
| Turbidity | APHA 20th Edition Method 2130 B. LAS official test 4.1, 5.04. | 0.01 NTU |
| Total Coliforms | Chromogenic Presence/Absence test following APHA 21st Edition 9223 B. MIMM 11A1.1. LAS official test 1.1.1 | 1 /100mL |
| E. coli | Chromogenic Presence/Absence test following APHA 21st Edition 9223 B. MIMM 11A1.1. LAS official test 1.1.1 | 1 /100mL |
| Fluoride | Ion Chromatography following USEPA 300.0 (modified). LAS official test 5.12. | 0.02 g/m3 |
| Chloride | Ion Chromatography following USEPA 300.0 (modified). LAS official test 5.11. | 0.02 g/m3 |
| Nitrate - Nitrogen | Ion Chromatography following USEPA 300.0 (modified). LAS official test 5.13. | 0.01 g/m3 |
| Sulphate | Ion Chromatography following USEPA 300.0 (modified). LAS official test 5.16. | 0.02 g/m3 |
| Arsenic - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified) | 0.005 g/m3 |
| Boron - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified) | 0.005 g/m3 |
| Calcium - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.21. | 0.01 g/m3 |
| Copper - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified) | 0.005 g/m3 |
| Iron - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.25. | 0.005 g/m3 |
| Magnesium - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.27. | 0.01 g/m3 |
| Manganese - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.28. | 0.005 g/m3 |
| Sodium - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.31. | 0.02 g/m3 |
| Zinc - Acid Soluble | ICP-OES following APHA 21st Edition Method 3120 B (modified) | 0.005 g/m3 |
| Total Hardness | ICP-OES following APHA 21st Edition Method 3120 B (modified). LAS official test 5.05. | 1 g/m3 |

"<" means that no analyte was found in the sample at the level of detection shown. Detection limits are based on a clean matrix and may vary according to individual sample.

g/m3 is the equivalent to mg/L and ppm.

Samples will be retained for a period of time, in suitable conditions appropriate to the analyses requested.

All test methods and confidence limits are available on request. This report must not be reproduced except in full, without the written consent of the laboratory.



Report Released By

Rob Deacon



414
639



This laboratory is accredited by International Accreditation New Zealand and its reports are recognised in all countries affiliated to the International Laboratory Accreditation Co-operation Mutual Recognition Arrangement (ILAC-MRA). The tests reported have been performed in accordance with our terms of accreditation, with the exception of tests marked "not IANZ", which are outside the scope of this laboratory's accreditation.

This report may not be reproduced except in full without the written approval of this laboratory.